

## Data for Air Monitoring at IGL Kashipur

### Ambient Air Quality

LOCATION NO	PARAMETERS			
	SPM	SO <sub>2</sub>	CO	NO <sub>x</sub>
1	62.50	NIL	NIL	NIL
2	45.49	NIL	NIL	NIL
3	30.62	NIL	NIL	NIL
4	24.43	NIL	NIL	NIL
5	21.41	NIL	NIL	NIL
6	34.04	NIL	NIL	NIL
7	71.83	NIL	NIL	NIL

### Stack Monitoring Results

BOILER NAME	PARAMETERS				
	SO <sub>2</sub>	HC	CO	SPM	Nox
CVL Boiler-20 T	158	ND	ND	132	1.3
IJT Boiler	150	ND	ND	445	5.2
TBW Boiler	162	ND	ND	124	1.4
Thermaax-80 T	134	ND	ND	126	1.2
CVL Boiler-30 T	160	ND	ND	134	1.4